



\*\*\* spare part \*\*\* SIMATIC S7-1500, CPU 1515-2 PN, central processing unit with work memory 500 KB for program and 3 MB for data, 1st interface: PROFINET IRT with 2-port switch, 2nd interface: PROFINET RT, 30 ns bit performance, SIMATIC Memory Card required

| General information  |  |
|--|--|
| Product type designation   | CPU 1515-2 PN  |
| HW functional status   | FS01   |
| Firmware version   | V2.9   |
| Product function   |  |
| <ul style="list-style-type: none"> <li>I&amp;M data</li> </ul>   | Yes; I&M0 to I&M3  |
| <ul style="list-style-type: none"> <li>Isochronous mode</li> </ul>                                       | Yes; Distributed and central; with minimum OB 6x cycle of 500 µs (distributed) and 1 ms (central)          |
| Engineering with   |  |
| <ul style="list-style-type: none"> <li>STEP 7 TIA Portal configurable/integrated from version</li> </ul> | V17 (FW V2.9) / V16 (FW V2.8) or higher; with older TIA Portal versions configurable as 6ES7515-2AM01-0AB0 |
| Configuration control  |  |
| via dataset  | Yes  |
| Display  |  |
| Screen diagonal [cm]   | 6.1 cm   |
| Control elements   |  |
| Number of keys   | 8  |
| Mode buttons   | 2  |
| Supply voltage   |  |
| Rated value (DC)   | 24 V   |
| permissible range, lower limit (DC)  | 19.2 V   |
| permissible range, upper limit (DC)  | 28.8 V   |
| Reverse polarity protection  | Yes  |
| Mains buffering  |  |
| <ul style="list-style-type: none"> <li>Mains/voltage failure stored energy time</li> </ul>               | 5 ms   |
| <ul style="list-style-type: none"> <li>Repeat rate, min.</li> </ul>                                      | 1/s  |
| Input current  |  |
| Current consumption (rated value)  | 0.8 A  |
| Current consumption, max.  | 1.1 A  |
| Inrush current, max.   | 2.4 A; Rated value   |
| $I^2t$   | 0.02 A <sup>2</sup> ·s   |
| Power  |  |
| Infeed power to the backplane bus  | 12 W   |
| Power consumption from the backplane bus (balanced)  | 6.2 W  |
| Power loss   |  |
| Power loss, typ.   | 6.3 W  |
| Memory   |  |
| Number of slots for SIMATIC memory card  | 1  |
| SIMATIC memory card required   | Yes  |

|   |   |
|---|---|
| <b>Work memory</b>  |   |
| • integrated (for program)                                | 500 kbyte   |
| • integrated (for data)                                   | 3 Mbyte   |
| <b>Load memory</b>  |   |
| • Plug-in (SIMATIC Memory Card), max.                     | 32 Gbyte  |
| <b>Backup</b>   |   |
| • maintenance-free  | Yes   |
| <b>CPU processing times</b>                               |   |
| for bit operations, typ.                                  | 30 ns   |
| for word operations, typ.                                 | 36 ns   |
| for fixed point arithmetic, typ.                          | 48 ns   |
| for floating point arithmetic, typ.                       | 192 ns  |
| <b>CPU-blocks</b>   |   |
| Number of elements (total)                                | 8 000; Blocks (OB, FB, FC, DB) and UDTs   |
| <b>DB</b>   |   |
| • Number range  | 1 ... 60 999; subdivided into: number range that can be used by the user: 1 ... 59 999, and number range of DBs created via SFC 86: 60 000 ... 60 999 |
| • Size, max.  | 3 Mbyte; For DBs with absolute addressing, the max. size is 64 KB   |
| <b>FB</b>   |   |
| • Number range  | 0 ... 65 535  |
| • Size, max.  | 500 kbyte   |
| <b>FC</b>   |   |
| • Number range  | 0 ... 65 535  |
| • Size, max.  | 500 kbyte   |
| <b>OB</b>   |   |
| • Size, max.  | 500 kbyte   |
| • Number of free cycle OBs                                | 100   |
| • Number of time alarm OBs                                | 20  |
| • Number of delay alarm OBs                               | 20  |
| • Number of cyclic interrupt OBs                          | 20; With minimum OB 3x cycle of 500 µs  |
| • Number of process alarm OBs                             | 50  |
| • Number of DPV1 alarm OBs                                | 3   |
| • Number of isochronous mode OBs                          | 2   |
| • Number of technology synchronous alarm OBs              | 2   |
| • Number of startup OBs                                   | 100   |
| • Number of asynchronous error OBs                        | 4   |
| • Number of synchronous error OBs                         | 2   |
| • Number of diagnostic alarm OBs                          | 1   |
| <b>Nesting depth</b>                                      |   |
| • per priority class                                      | 24  |
| <b>Counters, timers and their retentivity</b>             |   |
| <b>S7 counter</b>   |   |
| • Number  | 2 048   |
| <b>Retentivity</b>  |   |
| — adjustable  | Yes   |
| <b>IEC counter</b>  |   |
| • Number  | Any (only limited by the main memory)   |
| <b>Retentivity</b>  |   |
| — adjustable  | Yes   |
| <b>S7 times</b>   |   |
| • Number  | 2 048   |
| <b>Retentivity</b>  |   |
| — adjustable  | Yes   |
| <b>IEC timer</b>  |   |
| • Number  | Any (only limited by the main memory)   |
| <b>Retentivity</b>  |   |
| — adjustable  | Yes   |
| <b>Data areas and their retentivity</b>                   |   |
| Retentive data area (incl. timers, counters, flags), max. | 512 kbyte; In total; available retentive memory for bit memories, timers,   |

|  |   |
|--|---|
|  | counters, DBs, and technology data (axes): 472 KB   |
| Extended retentive data area (incl. timers, counters, flags), max. | 3 Mbyte; When using PS 6 0W 24/48/60 V DC HF  |
| <b>Flag</b>  |   |
| • Size, max.   | 16 kbyte  |
| • Number of clock memories   | 8; 8 clock memory bit, grouped into one clock memory byte   |
| <b>Data blocks</b>   |   |
| • Retentivity adjustable   | Yes   |
| • Retentivity preset   | No  |
| <b>Local data</b>  |   |
| • per priority class, max.   | 64 kbyte; max. 16 KB per block  |
| <b>Address area</b>  |   |
| Number of IO modules   | 8 192; max. number of modules / submodules  |
| <b>I/O address area</b>  |   |
| • Inputs   | 32 kbyte; All inputs are in the process image   |
| • Outputs  | 32 kbyte; All outputs are in the process image  |
| per integrated IO subsystem  |   |
| — Inputs (volume)  | 8 kbyte   |
| — Outputs (volume)   | 8 kbyte   |
| per CM/CP  |   |
| — Inputs (volume)  | 8 kbyte   |
| — Outputs (volume)   | 8 kbyte   |
| <b>Subprocess images</b>   |   |
| • Number of subprocess images, max.                                | 32  |
| <b>Hardware configuration</b>                                      |   |
| Number of distributed IO systems                                   | 64; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link) |
| <b>Number of DP masters</b>  |   |
| • Via CM   | 8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total   |
| <b>Number of IO Controllers</b>                                    |   |
| • integrated   | 2   |
| • Via CM   | 8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total   |
| <b>Rack</b>  |   |
| • Modules per rack, max.   | 32; CPU + 31 modules  |
| • Number of lines, max.  | 1   |
| <b>PtP CM</b>  |   |
| • Number of PtP CMs  | the number of connectable PtP CMs is only limited by the number of available slots  |
| <b>Time of day</b>   |   |
| <b>Clock</b>   |   |
| • Type   | Hardware clock  |
| • Backup time  | 6 wk; At 40 °C ambient temperature, typically   |
| • Deviation per day, max.  | 10 s; Typ.: 2 s   |
| <b>Operating hours counter</b>                                     |   |
| • Number   | 16  |
| <b>Clock synchronization</b>                                       |   |
| • supported  | Yes   |
| • in AS, master  | Yes   |
| • in AS, device  | Yes   |
| • on Ethernet via NTP  | Yes   |
| <b>Interfaces</b>  |   |
| Number of PROFINET interfaces                                      | 2   |
| <b>1. Interface</b>  |   |
| <b>Interface types</b>   |   |
| • RJ 45 (Ethernet)   | Yes; X1   |
| • Number of ports  | 2   |
| • integrated switch  | Yes   |
| <b>Protocols</b>   |   |

|                          |                                |
|--------------------------|--------------------------------|
| • IP protocol            | Yes; IPv4                      |
| • PROFINET IO Controller | Yes                            |
| • PROFINET IO Device     | Yes                            |
| • SIMATIC communication  | Yes                            |
| • Open IE communication  | Yes; Optionally also encrypted |
| • Web server             | Yes                            |
| • Media redundancy       | Yes                            |

### PROFINET IO Controller

|   |  |
|---|--|
| Services  |  |
| — PG/OP communication   | Yes  |
| — Isochronous mode  | Yes  |
| — Direct data exchange  | Yes; Requirement: IRT and isochronous mode (MRPD optional)   |
| — IRT   | Yes  |
| — PROFINergy  | Yes; per user program  |
| — Prioritized startup   | Yes; Max. 32 PROFINET devices  |
| — Number of connectable IO Devices, max.                                      | 256; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET   |
| — Of which IO devices with IRT, max.  | 64   |
| — Number of connectable IO Devices for RT, max.                               | 256  |
| — of which in line, max.  | 256  |
| — Number of IO Devices that can be simultaneously activated/deactivated, max. | 8; in total across all interfaces  |
| — Number of IO Devices per tool, max.   | 8  |
| — Updating times  | The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data |

|  |   |
|--|---|
| Update time for IRT                                  |   |
| — for send cycle of 250 µs                           | 250 µs to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 500 µs of the isochronous OB is decisive |
| — for send cycle of 500 µs                           | 500 µs to 8 ms  |
| — for send cycle of 1 ms                             | 1 ms to 16 ms   |
| — for send cycle of 2 ms                             | 2 ms to 32 ms   |
| — for send cycle of 4 ms                             | 4 ms to 64 ms   |
| — With IRT and parameterization of "odd" send cycles | Update time = set "odd" send clock (any multiple of 125 µs: 375 µs, 625 µs ... 3 875 µs)  |

|                            |                  |
|----------------------------|------------------|
| Update time for RT         |                  |
| — for send cycle of 250 µs | 250 µs to 128 ms |
| — for send cycle of 500 µs | 500 µs to 256 ms |
| — for send cycle of 1 ms   | 1 ms to 512 ms   |
| — for send cycle of 2 ms   | 2 ms to 512 ms   |
| — for send cycle of 4 ms   | 4 ms to 512 ms   |

### PROFINET IO Device

|   |                       |
|---|-----------------------|
| Services  |                       |
| — PG/OP communication                               | Yes                   |
| — Isochronous mode                                  | No                    |
| — IRT   | Yes                   |
| — PROFINergy  | Yes; per user program |
| — Shared device                                     | Yes                   |
| — Number of IO Controllers with shared device, max. | 4                     |
| — activation/deactivation of I-devices              | Yes; per user program |
| — Asset management record                           | Yes; per user program |

## 2. Interface

|                     |         |
|---------------------|---------|
| Interface types     |         |
| • RJ 45 (Ethernet)  | Yes; X2 |
| • Number of ports   | 1       |
| • integrated switch | No      |

|                          |           |
|--------------------------|-----------|
| Protocols                |           |
| • IP protocol            | Yes; IPv4 |
| • PROFINET IO Controller | Yes       |
| • PROFINET IO Device     | Yes       |
| • SIMATIC communication  | Yes       |

|   |  |
|---|--|
| • Open IE communication   | Yes; Optionally also encrypted   |
| • Web server  | Yes  |
| • Media redundancy  | No   |
| <b>PROFINET IO Controller</b>   |  |
| <b>Services</b>   |  |
| — PG/OP communication   | Yes  |
| — Isochronous mode  | No   |
| — Direct data exchange  | No   |
| — IRT   | No   |
| — PROFIenergy   | Yes; per user program  |
| — Prioritized startup   | No   |
| — Number of connectable IO Devices, max.                                      | 32; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET  |
| — Number of connectable IO Devices for RT, max.                               | 32   |
| — of which in line, max.  | 32   |
| — Number of IO Devices that can be simultaneously activated/deactivated, max. | 8; in total across all interfaces  |
| — Number of IO Devices per tool, max.   | 8  |
| — Updating times  | The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data |
| <b>Update time for RT</b>   |  |
| — for send cycle of 1 ms  | 1 ms to 512 ms   |
| <b>PROFINET IO Device</b>   |  |
| <b>Services</b>   |  |
| — PG/OP communication   | Yes  |
| — Isochronous mode  | No   |
| — IRT   | No   |
| — PROFIenergy   | Yes; per user program  |
| — Prioritized startup   | No   |
| — Shared device   | Yes  |
| — Number of IO Controllers with shared device, max.                           | 4  |
| — activation/deactivation of I-devices  | Yes; per user program  |
| — Asset management record   | Yes; per user program  |
| <b>Interface types</b>  |  |
| <b>RJ 45 (Ethernet)</b>   |  |
| • 100 Mbps  | Yes  |
| • Autonegotiation   | Yes  |
| • Autocrossing  | Yes  |
| • Industrial Ethernet status LED  | Yes  |
| <b>Protocols</b>  |  |
| PROFIsafe   | No   |
| <b>Number of connections</b>  |  |
| • Number of connections, max.   | 192; via integrated interfaces of the CPU and connected CPs / CMs  |
| • Number of connections reserved for ES/HMI/web                               | 10   |
| • Number of connections via integrated interfaces                             | 108  |
| • Number of S7 routing paths  | 16   |
| <b>Redundancy mode</b>  |  |
| • H-Sync forwarding   | Yes  |
| <b>Media redundancy</b>   |  |
| — Media redundancy  | only via 1st interface (X1)  |
| — MRP   | Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP Manager; MRP Client   |
| — MRP interconnection, supported  | Yes; as MRP ring node according to IEC 62439-2 Edition 3.0   |
| — MRPD  | Yes; Requirement: IRT  |
| — Switchover time on line break, typ.   | 200 ms; For MRP, bumpless for MRPD   |
| — Number of stations in the ring, max.  | 50   |
| <b>SIMATIC communication</b>  |  |
| • PG/OP communication   | Yes; encryption with TLS V1.3 pre-selected   |
| • S7 routing  | Yes  |

|  |   |
|--|---|
| • S7 communication, as server  | Yes   |
| • S7 communication, as client  | Yes   |
| • User data per job, max.  | See online help (S7 communication, user data size)                              |
| <b>Open IE communication</b>   |   |
| • TCP/IP   | Yes   |
| — Data length, max.  | 64 kbyte  |
| — several passive connections per port, supported  | Yes   |
| • ISO-on-TCP (RFC1006)   | Yes   |
| — Data length, max.  | 64 kbyte  |
| • UDP  | Yes   |
| — Data length, max.  | 2 kbyte; 1 472 bytes for UDP broadcast  |
| — UDP multicast  | Yes; Max. 5 multicast circuits  |
| • DHCP   | Yes   |
| • DNS  | Yes   |
| • SNMP   | Yes   |
| • DCP  | Yes   |
| • LLDP   | Yes   |
| • Encryption   | Yes; Optional   |
| <b>Web server</b>  |   |
| • HTTP   | Yes; Standard and user pages  |
| • HTTPS  | Yes; Standard and user pages  |
| <b>OPC UA</b>  |   |
| • Runtime license required   | Yes; "Medium" license required  |
| • OPC UA Client  | Yes   |
| — Application authentication   | Yes   |
| — Security policies  | Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 |
| — User authentication  | "anonymous" or by user name & password  |
| — Number of connections, max.  | 10  |
| — Number of nodes of the client interfaces, recommended max.   | 2 000   |
| — Number of elements for one call of OPC-UA_NodeGetHandleList/OPC-UA_ReadList/OPC-UA_WriteList, max.   | 300   |
| — Number of elements for one call of OPC-UA_NameSpaceGetIndexList, max.                                | 20  |
| — Number of elements for one call of OPC-UA_MethodGetHandleList, max.                                  | 100   |
| — Number of simultaneous calls of the client instructions for session management, per connection, max. | 1   |
| — Number of simultaneous calls of the client instructions for data access, per connection, max.        | 5   |
| — Number of registerable nodes, max.   | 5 000   |
| — Number of registerable method calls of OPC-UA_MethodCall, max.                                       | 100   |
| — Number of inputs/outputs when calling OPC-UA_MethodCall, max.  | 20  |
| • OPC UA Server  | Yes; Data access (read, write, subscribe), method call, custom address space    |
| — Application authentication   | Yes   |
| — Security policies  | Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 |
| — User authentication  | "anonymous" or by user name & password  |
| — GDS support (certificate management)   | Yes   |
| — Number of sessions, max.   | 48  |
| — Number of accessible variables, max.   | 100 000   |
| — Number of registerable nodes, max.   | 20 000  |
| — Number of subscriptions per session, max.  | 20  |
| — Sampling interval, min.  | 100 ms  |
| — Publishing interval, min.  | 200 ms  |
| — Number of server methods, max.   | 50  |
| — Number of inputs/outputs per server method, max.   | 20  |

|   |   |
|---|---|
| — Number of monitored items, recommended max.                         | 2 000; for 1 s sampling interval and 1 s send interval  |
| — Number of server interfaces, max.                                   | 10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"                          |
| — Number of nodes for user-defined server interfaces, max.            | 5 000   |
| • Alarms and Conditions   | Yes   |
| — Number of program alarms  | 200   |
| — Number of alarms for system diagnostics                             | 100   |
| <b>Further protocols</b>  |   |
| • MODBUS  | Yes; MODBUS TCP   |
| <b>Isochronous mode</b>   |   |
| Equidistance  | Yes   |
| <b>S7 message functions</b>   |   |
| Number of login stations for message functions, max.                  | 64  |
| Program alarms  | Yes   |
| Number of configurable program messages, max.                         | 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH   |
| Number of loadable program messages in RUN, max.                      | 5 000   |
| Number of simultaneously active program alarms                        |   |
| • Number of program alarms  | 800   |
| • Number of alarms for system diagnostics                             | 200   |
| • Number of alarms for motion technology objects                      | 160   |
| <b>Test commissioning functions</b>                                   |   |
| Joint commission (Team Engineering)                                   | Yes; Parallel online access possible for up to 8 engineering systems  |
| Status block  | Yes; Up to 8 simultaneously (in total across all ES clients)  |
| Single step   | No  |
| Number of breakpoints   | 8   |
| <b>Status/control</b>   |   |
| • Status/control variable   | Yes   |
| • Variables   | Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters  |
| • Number of variables, max.   |   |
| — of which status variables, max.                                     | 200; per job  |
| — of which control variables, max.                                    | 200; per job  |
| <b>Forcing</b>  |   |
| • Forcing   | Yes   |
| • Forcing, variables  | Peripheral inputs/outputs   |
| • Number of variables, max.   | 200   |
| <b>Diagnostic buffer</b>  |   |
| • present   | Yes   |
| • Number of entries, max.   | 3 200   |
| — of which powerfail-proof  | 500   |
| <b>Traces</b>   |   |
| • Number of configurable Traces                                       | 4; Up to 512 KB of data per trace are possible  |
| <b>Interrupts/diagnostics/status information</b>                      |   |
| <b>Diagnostics indication LED</b>                                     |   |
| • RUN/STOP LED  | Yes   |
| • ERROR LED   | Yes   |
| • MAINT LED   | Yes   |
| • STOP ACTIVE LED   | Yes   |
| • Connection display LINK TX/RX                                       | Yes   |
| <b>Supported technology objects</b>                                   |   |
| Motion Control  | Yes; Note: The number of technology objects affects the cycle time of the PLC program; selection guide via the TIA Selection Tool |
| • Number of available Motion Control resources for technology objects | 2 400   |
| • Required Motion Control resources                                   |   |
| — per speed-controlled axis   | 40  |
| — per positioning axis  | 80  |
| — per synchronous axis  | 160   |
| — per external encoder  | 80  |

|  |  |
|--|--|
| — per output cam   | 20   |
| — per cam track  | 160  |
| — per probe  | 40   |
| • Positioning axis   |  |
| — Number of positioning axes at motion control cycle of 4 ms (typical value) | 7  |
| — Number of positioning axes at motion control cycle of 8 ms (typical value) | 14   |
| Controller   |  |
| • PID_Compact  | Yes; Universal PID controller with integrated optimization       |
| • PID_3Step  | Yes; PID controller with integrated optimization for valves      |
| • PID-Temp   | Yes; PID controller with integrated optimization for temperature |
| Counting and measuring   |  |
| • High-speed counter   | Yes  |

### Ambient conditions

|   |  |
|---|--|
| Ambient temperature during operation              |  |
| • horizontal installation, min.                   | -25 °C; No condensation  |
| • horizontal installation, max.                   | 60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off |
| • vertical installation, min.                     | -25 °C; No condensation  |
| • vertical installation, max.                     | 40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off |
| Ambient temperature during storage/transportation |  |
| • min.  | -40 °C   |
| • max.  | 70 °C  |
| Altitude during operation relating to sea level   |  |
| • Installation altitude above sea level, max.     | 5 000 m; Restrictions for installation altitudes > 2 000 m, see manual                             |

### Configuration

|   |                               |
|---|-------------------------------|
| Programming                                     |                               |
| Programming language                            |                               |
| — LAD   | Yes                           |
| — FBD   | Yes                           |
| — STL   | Yes                           |
| — SCL   | Yes                           |
| — GRAPH   | Yes                           |
| Know-how protection                             |                               |
| • User program protection/password protection   | Yes                           |
| • Copy protection                               | Yes                           |
| • Block protection                              | Yes                           |
| Access protection                               |                               |
| • protection of confidential configuration data | Yes                           |
| • Password for display                          | Yes                           |
| • Protection level: Write protection            | Yes                           |
| • Protection level: Read/write protection       | Yes                           |
| • Protection level: Complete protection         | Yes                           |
| Cycle time monitoring                           |                               |
| • lower limit                                   | adjustable minimum cycle time |
| • upper limit                                   | adjustable maximum cycle time |
| Dimensions                                      |                               |
| Width   | 70 mm                         |
| Height  | 147 mm                        |
| Depth   | 129 mm                        |
| Weights   |                               |
| Weight, approx.                                 | 830 g                         |

### Classifications

|        | Version | Classification |
|--------|---------|----------------|
| eClass | 14      | 27-24-22-07    |
| eClass | 12      | 27-24-22-07    |
| eClass | 9.1     | 27-24-22-07    |

|        |     |             |
|--------|-----|-------------|
| eClass | 9   | 27-24-22-07 |
| eClass | 8   | 27-24-22-07 |
| eClass | 7.1 | 27-24-22-07 |
| eClass | 6   | 27-24-22-07 |
| ETIM   | 10  | EC000236    |
| ETIM   | 9   | EC000236    |
| ETIM   | 8   | EC000236    |
| ETIM   | 7   | EC000236    |
| IDEA   | 4   | 3565        |
| UNSPSC | 15  | 32-15-17-05 |

**Approvals / Certificates**

**General Product Approval**



[Manufacturer Declaration](#)

[Miscellaneous](#)

[China RoHS](#)



**General Product Approval**

**For use in hazardous locations**

[Miscellaneous](#)



[EM](#)

[CCC-Ex](#)

**For use in hazardous locations**

**Maritime application**



[Type Examination Certificate](#)

[Miscellaneous](#)

[CCC-Ex](#)



**Maritime application**



[NK / Nippon Kaiji Kyokai](#)



**Maritime application**

**other**

**Industrial Communication**

[CCS \(China Classification Society\)](#)

[KR \(Korean Register of Shipping\)](#)

[PROFINET](#)

[PROFINET](#)

last modified:

7/31/2025